

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-0328:162 Page 1 of 1

CATEGORY: Audible Signal Device

LISTEE: Potter, 2081 Craig Road, St. Louis, MO 63146
Contact: Brad Serangeli (314) 878-4321

DESIGN: Models PMBD-246, PMBD-248, PMBD-2410, PVBA-246, PVBA-1206, PVBA-248, PVBA-1208, PVBA-2410 and PVBA-12010 bells. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: PMBD-246, MMBD-248, PMBD-2410: 24 VDC
PVBA-246, PVBA-1206, PVBA-248, PVBA-1208, PVBA-2410,
and PVBA-12010: 24VAC or 120VAC
Gong size: 6", 8" or 10"

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical and audibility ratings and UL label.

APPROVAL: Listed as bells for use with separately listed compatible fire alarm control units. Suitable for outdoor use when installed with Models BBX-1 and BBX-4 back box.

XLF: 7135-0587:117

03-13-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 20, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager